

**REGIONAL ADVANCE WATER TESTING LABORATORY, PHASE 2- SAS
NAGAR**

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
rawtlmohali@gmail.com

To,

Principal
The Whiteflied School Bathinda

No.: RAWTL/2627/00301 Dated : 21/08/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Dated: 15/08/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/08/2026. It is request to fill the attached feedback form and send it back to Regional Advance Water Testing Laboratory, Phase 2- SAS Nagar

D/A : Test Report



**Authorized Signatory
For, Regional Advance Water Testing
Laboratory
Phase 2- SAS Nagar**

REGIONAL ADVANCE WATER TESTING LABORATORY, PHASE 2- SAS NAGAR

Water Works Complex, Phase- 2, S.A.S NAGAR , Punjab
rawtlmohali@gmail.com



TEST REPORT						
Name & Address of Customer : Principal The Whitefied School Bathinda			Customer Reference No.		No : Dated : 15/08/2026	
			Sample Submitted by		shiv pratap	
			Date of Sample Receipt		15/08/2026	
			Analysis Starting Date		19/08/2026	
			Analysis completion Date		20/08/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:		TC130272600000090F		Sample Type :		RO Water
Test Report No.:		RAWTL/2627/00137		Date of Issue :		21/08/2026
Registration no.:		RAWTL/REG2627/01091		Condition of Sample :		Unsealed
Collection Point:		NA		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		The Whitefied School Bathinda / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Bathinda
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	BDL(0.005)	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	BDL(0.010)	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	BDL(5)	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Signature

Mr. Satyender Singh
Sr. Chemist
Authorized Signatory
For,Regional Advance Water Testing Laboratory
Phase 2- SAS Nagar

-----End of the Test Report-----

Principal
The Whitefield School Bathinda
Maniana Highway Bathinda